

CONFIDENTIAL



UTHM

Universiti Tun Hussein Onn Malaysia

UNIVERSITI TUN HUSSEIN ONN MALAYSIA

**FINAL EXAMINATION
(ONLINE)
SEMESTER II
SESSION 2019/2020**

COURSE NAME : WASTEWATER ENGINEERING DESIGN
COURSE CODE : BFA40403
PROGRAMME CODE : BFF
EXAMINATION DATE : JULY 2020
DURATION : 6 HOURS
INSTRUCTION : ANSWER **FOUR (4)** QUESTIONS ONLY

THIS QUESTION PAPER CONSISTS OF **FIVE (5)** PAGES

CONFIDENTIAL

TERBUKA

- Q1** (a) A mechanical bar screen is to be used in an approach channel with a maximum velocity of 0.65 m/s, and a peak design flow of 0.631 m³/s. The bars are 10 mm width and openings are 25 mm wide, the angle of inclination is 60°. Determine:
- (i) The cross section of the bar screen, and the dimension needed if the upstream depth of wastewater is 1.12 m. (4 marks)
 - (ii) The number of bars. (3 marks)
 - (iii) The inclined length of bars. (3 marks)
- (b) Design an aerated grit chamber for the treatment of municipal wastewater. The average flow rate is 0.473 m³/s and the peak flow is 2.29 times the average flow. Determine.
- (i) The grit chamber volume if the average detention time at the peak flow rate is 3 minutes. Provide two chambers to facilitate periodic cleaning and maintenance. (5 marks)
 - (ii) The dimensions of each grit chamber. The grit chamber width is 1.5 times the depth, and the length is 4 times the width. (5 marks)
 - (iii) The air supply requirement if 0.3m³/min per meter of grit chamber length is to be provided. (3 marks)
 - (iv) The quantity of grit at peak flow. Assume a value of 0.015 m³/10³ m³ at peak flow. (2 marks)
- Q2** A primary sedimentation tank for a municipal wastewater treatment plant is to be designed for an average flow of 8,000 m³/d. The regulatory agency criteria for primary sedimentation tanks are as follows: peak overflow rate = 40 m³/m²-d, minimum side water depth = 4 m, and channel width = 6 m. The ratio of the peak hourly flow to the average hourly flow is 2.5. Calculate:
- (i) The required surface area of the sedimentation tank. Use a minimum of **TWO (2)** sedimentation tanks. (5 marks)

- (ii) The tank length and tank volume. (5 marks)
- (iii) The detention time and overflow rate at peak flow. (5 marks)
- (iv) The scour velocity if the diameter of particles is $100\ \mu\text{m}$. Use $s = 1.25$, $f = 0.025$, $g = 9.81\ \text{m/s}^2$ and $k = 0.05$. Compare the scour velocity to the peak flow horizontal velocity. (5 marks)
- (v) The removal rate of BOD and TSS at peak flow. Assume the empirical constants for BOD ($a = 0.018$, $b = 0.020$) and TSS ($a = 0.0075$, $b = 0.014$). (5 marks)

Q3 Design a Sequencing Batch Reactor (SBR) process to treat a domestic wastewater using the following design data:

Design condition and assumptions:

Use 2 SBR tanks

Design flow rate = $22,700\ \text{m}^3/\text{d}$

Total liquid depth when full = 6 m

Decant depth = 30% of tank depth

MLSS = 3000 mg/L

Settled sludge concentration = 6,000 mg/L

Clear liquid above the sludge blanket = 35%

Anoxic fill = 135 min

Aerated fill = 45 min

React = 90 min

Settle = 45 min

Decant = 30 min

Idle = 15 min

Determine:

- (i) The fill volume for one SBR. (6 marks)
- (ii) The fill fraction per cycle. (6 marks)
- (iii) The volume of the tank. (4 marks)

(iv) The dimensions of the tank. (4 marks)

(v) The overall hydraulic retention time. (5 marks)

Q4 (a) Explain briefly **FIVE (5)** basic processes for sludge treatment. (5 marks)

(b) Determine the daily primary sludge production for a wastewater treatment plant having the following operating characteristics:

- Operating Data:
 Flow = 0.0500 m³/s
 Influent Suspended Solids = 155 mg/L
 Removal efficiency = 53%
 Volatile solids = 70%
 Specific gravity of volatile solids = 0.970
 Fixed solids = 30%
 Specific gravity of fixed solids = 2.50
 Sludge concentration = 4.50%

(10 marks)

(c) Design a gravity thickener for a wastewater treatment plant having primary and waste activated sludge with the following characteristics:

Type of sludge	Specific gravity	Solids, %	Flowrate, m ³ /d
Average design conditions:			
Primary sludge	1.03	3.3	400
Waste activated	1.005	0.2	2250
Peak design conditions:			
Primary sludge	1.03	3.4	420
Waste Activated	1.005	0.23	2500

- Assume:
 Specific gravity of the combined sludge = 1.02
 Solids loading rate = 50 kg/m².d
 Provide two thickeners

(10 marks)



- Q5** Anaerobically digested sludge from a wastewater treatment facility is to be treated by land application to an agricultural site at which corn will be grown. The wastewater treatment plant serves a population of 10,000 persons and produces 200 metric tons of dry sludge per year. The sludge will be applied as a liquid by surface distribution. The design is to be based on the nitrogen needs of the corn crop and is to be limited by a cumulative cadmium loading of 11 kg Cd/ha for the length of time the site can be used. The sludge contains 100 mgCd/kg of dry sludge, 1% ammonia nitrogen, 2.2% organic nitrogen and no nitrate nitrogen.

Assume:

Mineralization rate for the first year = 0.20

Mineralization rate for the second year = 0.10

Mineralization rate for the third year = 0.05

Mineralization rate for the fourth to eighth years = 0.03

Volatilization factor, $k_v = 0.5$

Nitrogen uptake rate for corn, $U_n = 180$ kg-N/ha-yr

Conversion constant = 1000 kg/mt

Determine:

- (i) The allowable annual dry sludge application rate. The nitrogen available from mineralization is negligible after the ninth year. (10 marks)
- (ii) The cadmium-limited allowable amount of sludge. (5 marks)
- (iii) The land area required. (5 marks)
- (iv) The design life of the site for sludge application. (5 marks)

– END OF QUESTIONS –