



UNIVERSITI TUN HUSSEIN ONN MALAYSIA

**FINAL EXAMINATION
SEMESTER I
SESSION 2019/2020**

COURSE NAME : HEATING, VENTILATING & AIR
CONDITIONING SYSTEM

COURSE CODE : BNB 31203

PROGRAMME CODE : BNB

EXAMINATION DATE : DECEMBER 2019/JANUARY 2020

DURATION : 3 HOURS

INSTRUCTION : ANSWER ALL QUESTIONS

TERBUKA

THIS QUESTION PAPER CONSISTS OF SIXTEEN (16) PAGES

- Q1** (a) Define the term of heating, ventilating and air-conditioning. (3 marks)
- (b) **Figure Q1 (b)** shows the basic cycle of the refrigeration system. Explain the process from point (1) until point (8). (8 marks)
- (c) Discuss the effect of thermal conductivity in heat transfer. (6 marks)
- (d) Differentiate between natural and mechanical ventilation. Give **TWO (2)** example for each categories. (8 marks)
- Q2** (a) A cooling tower is the basic piece of equipment used in a cooling system. Illustrate and briefly describe the cooling tower working principle. (5 marks)
- (b) Differentiate between all air system, all water system and air-water system. (9 marks)
- (c) Putra Holding Company Limited uses a centralized air conditioning system. It uses ducting system to deliver and distribute cold air. There are several numbers of offices and meeting rooms which receive the cold air exceeding the required capacity of a room.
- (i) List **TWO (2)** reasons of the above problems. (2 marks)
- (ii) Propose **THREE (3)** solution for these issues. Use aid of diagram to support your answer. (9 marks)
- Q3** (a) Explain the purpose of cooling load calculation. (4 marks)
- (b) The floor plan of a mid-floor classroom in a multi-floor university as shown in **Figure Q3 (b)**. Calculate the total heat gain by using:

TERBUKA

- (i) Rule of thumb. (Refer **Appendix 1**) (4 marks)
- (ii) Calculation. (Refer **Appendix 2** and **Appendix 3**) (12 marks)
- (c) Determine the overall coefficient of heat transmission (U) for a face brick consisting of 2 inch cement plaster on both side, and 4.5 inch face brick as shown in **Figure Q3 (c)**. (Refer **Appendix 4** and **Appendix 5**) (5 marks)
- Q4** (a) Describe **TWO (2)** importance of Psychrometric chart in HVAC industries. (4 marks)
- (b) Outside air at a 40°F DB temperature and 60% RH is heated to a 90°F DB temperature. If no humidification equipment is used. Determine:
(Attach **Appendix 6** to support your answer)
- (i) the RH of the treated air. (3 marks)
- (ii) the heat added per lb. of air. (3marks)
- (iii) with same condition as above, if a humidifier is operated to maintain 50% RH. Calculate the heat added per lb. of air. (4 marks)
- (c) District cooling system (DCS) is a future-proof system that efficiently cools buildings through centralized distribution of chilled water.
- (i) With aid of diagram, explain the work principle of DCS. (5 marks)
- (ii) Discuss the relation of DCS and energy efficiency. (6 marks)

– END OF QUESTIONS –

TERBUKA

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203





Figure Q1 (b)



Specifications of construction

- Building : Five-story building
- Outside wall : Medium construction (concrete block 150mm t)
- Window glass : Normal (6mm t) with blind
- Floor : Concrete with linoleum
- Ceiling : Only concrete
- Lights : Flourescent light (40w×20=800w)
- Persons : 15 (working)
- Area : Standard temperature area

* * * Adjoined upper and lower rooms are not cooled.

TERBUKA

Figure Q3 (b)

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
COURSE NAME : HEATING, VENTILATING & AIR
CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
COURSE CODE : BNB 31203




Figure Q2 (a)

TERBUKA

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

Table 1 --- Design and Cooling Load Check Figures

| Applications | Occupancy Sq Ft/Person | | Lighting Watts/Sq Ft | | Fresh CFM/Person | | Air CFM/Sq Ft | | Room Sensible BtuHr/Sq Ft | | Room Total BtuHr/Sq Ft | | Grand Total BtuHr/Sq Ft | | Refrigeration Sq Ft/Ton* | | Supply Air CFM/Sq Ft | | |
|--|---------------------------|-----|-------------------------|-------|---------------------|-----|------------------|-----|---------------------------------|-----|---------------------------|-----|----------------------------|-----|-----------------------------|-----|-------------------------|------|------|
| | Lo | Avg | Lo | Hi | Lo | Avg | Lo | Hi | Lo | Avg | Lo | Hi | Lo | Avg | Lo | Hi | Lo | Hi | |
| Apartments (Flats) Auditoriums, Theaters | 150 | 100 | 1.0 | 2.0 | 4.0 | 2.5 | 3.5 | 5.0 | 25 | 45 | 20 | 30 | 30 | 40 | 60 | 300 | 200 | 75 | 1.25 |
| | 15 | 10 | 1.0 | 2.0 | 3.0 | 5.0 | 1.5 | 2.5 | 35 | 50 | 45 | 55 | 60 | 80 | 120 | 200 | 150 | 1.25 | 1.5 |
| Educational Facilities Classrooms | 30 | 25 | 2.0 | 4.0 | 6.0 | 5.0 | 7.5 | 10 | 20 | 40 | 25 | 35 | 45 | 60 | 80 | 275 | 200 | 150 | 1.0 |
| | 75 | 60 | 2.0 | 3.0 | 6.0 | 10 | 15 | 20 | 40 | 55 | 35 | 45 | 65 | 75 | 110 | 225 | 150 | 1.0 | 1.4 |
| Laboratories Cafeteria - Coffee House | 20 | 15 | 1.5 | 3.0 | 4.5 | 7.5 | 10 | 15 | 40 | 65 | 35 | 60 | 75 | 80 | 110 | 225 | 150 | 1.0 | 1.5 |
| | 50 | 35 | 3.0 | 4.5 | 6.0 | 5.0 | 10 | 15 | 25 | 75 | 30 | 60 | 85 | 90 | 130 | 240 | 150 | 1.0 | 2.25 |
| Factories Public Areas | 200 | 150 | 9.0† | 10.0† | 12.0† | 5.0 | 10 | 15 | 0.5 | 55 | 40 | 60 | 80 | 80 | 170 | 200 | 150 | 1.5 | 2.75 |
| | 300 | 250 | 15.0† | 45.0† | 60.0† | 5.0 | 10 | 15 | 0.3 | 115 | 80 | 120 | 160 | 150 | 200 | 100 | 80 | 3.0 | 4.0 |
| Light Manufacturing Heavy Manufacturing** | 20 | 15 | 1.0 | 1.5 | 2.0 | 5.0 | 10 | 15 | 0.75 | 50 | 40 | 50 | 70 | 60 | 85 | 200 | 150 | 1.0 | 1.1 |
| | 100 | 60 | 1.0 | 2.0 | 3.0 | 7.5 | 99 | 100 | 7.5 | 35 | 50 | 20 | 40 | 55 | 60 | 120 | 165 | 75 | 1.2 |
| Hospitals Patient Rooms† | 130 | 100 | 2.0 | 3.0 | 4.0 | 10 | 20 | 30 | 25 | 15 | 15 | 20 | 30 | 30 | 45 | 100 | 75 | 75 | 1.2 |
| | 150 | 100 | 2.0 | 5.0 | 10.0 | 20 | 30 | 50 | 10 | 45 | 30 | 55 | 70 | 45 | 70 | 100 | 275 | 120 | 1.7 |
| Laboratories Libraries | 150 | 100 | 2.0 | 4.0 | 6.0 | 5.0 | 7.5 | 10 | 20 | 30 | 20 | 35 | 45 | 30 | 45 | 70 | 175 | 175 | 1.1 |
| | 150 | 100 | 2.0 | 4.0 | 6.0 | 20 | 25 | 30 | 25 | 40 | 60 | 65 | 80 | 45 | 60 | 300 | 200 | 150 | 1.4 |
| Doctors Clinics Offices | 150 | 100 | 2.0 | 4.0 | 6.0 | 20 | 25 | 30 | 25 | 40 | 25 | 40 | 50 | 60 | 80 | 300 | 200 | 150 | 1.0 |
| | 125 | 100 | 4.0 | 6.0 | 8.0 | 20 | 25 | 30 | 25 | 75 | 30 | 55 | 80 | 40 | 75 | 90 | 175 | 135 | 1.7 |
| Private General - Perimeter | 125 | 100 | 4.0 | 6.0 | 8.0 | 10 | 15 | 20 | 15 | 35 | 25 | 40 | 50 | 30 | 45 | 400 | 250 | 150 | 1.0 |
| | 45 | 30 | 4.0 | 6.0 | 8.0 | 20 | 30 | 50 | 40 | 80 | 20 | 35 | 50 | 30 | 40 | 475 | 400 | 300 | 1.1 |
| Conference Rooms Restaurants | 25 | 20 | 1.5 | 1.7 | 2.0 | 10 | 15 | 20 | 15 | 30 | 40 | 50 | 60 | 85 | 120 | 200 | 150 | 1.0 | 1.5 |
| | 45 | 40 | 3.0† | 5.0† | 9.0† | 7.5 | 15 | 20 | 20 | 55 | 30 | 40 | 60 | 50 | 60 | 250 | 200 | 150 | 1.25 |
| Shopping Centers Beauty & Barber Shops | 40 | 30 | 4.0 | 5.0 | 5.0 | 5.0 | 7.5 | 10 | 20 | 30 | 45 | 50 | 35 | 45 | 60 | 325 | 275 | 200 | 1.4 |
| | 40 | 25 | 4.0 | 6.0† | 9.0† | 5.0 | 7.5 | 10 | 15 | 35 | 30 | 40 | 50 | 60 | 300 | 250 | 200 | 1.0 | |
| Department Stores - Basement - Main Floor | 80 | 50 | 2.0 | 4.0 | 6.0† | 5.0 | 5.0 | 7.5 | 25 | 35 | 20 | 30 | 40 | 50 | 400 | 300 | 250 | 80 | 1.2 |
| | 40 | 30 | 2.0 | 3.0 | 4.0 | 10 | 15 | 20 | 25 | 45 | 40 | 45 | 55 | 60 | 75 | 200 | 180 | 160 | 1.25 |
| - Upper Floors Specialty Shops | 40 | 25 | 3.0 | 4.0 | 6.0 | 5.0 | 7.5 | 10 | 15 | 35 | 40 | 50 | 60 | 50 | 60 | 300 | 250 | 200 | 1.0 |
| | 60 | 40 | 3.0 | 1.0 | 1.5 | 2.0 | 5.0 | 7.5 | 10 | 15 | 20 | 30 | 25 | 30 | 40 | 500 | 400 | 300 | 1.2 |
| 60 | 50 | 4.0 | 2.0 | 3.0 | 4.0 | 5.0 | 7.5 | 10 | 20 | 30 | 40 | 50 | 60 | 300 | 250 | 200 | 1.2 | 1.4 | |

† Includes other equipment loads expressed in watts/sq ft.
 ** Air quantities for heavy manufacturing areas are based on supplementary means to remove excessive heat.

* Refrigeration loads are for entire application.
 † Air quantities shown are for all-air systems.

Appendix 1

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

COOLING LOAD FORM

NAME OF COSNTRUCTOR:
 ADDRESS:
 NAME OF ROOM:

NAME OF PERSON INCHARGE:
 ROOM AREA:
 ROOM VOLUME:

| ITEMS | AREA (A) | COOLING | | | | |
|---------------------------|-------------------------|-----------------|-------------------|----------------------|-----------------|---|
| | | Coefficient (B) | C = A x B | Coefficient (F) | Load, Q = F x C | |
| WALL FACED TO THE OUTDOOR | m ² | | | 1 | | |
| | m ² | | | | | |
| | m ² | | | | | |
| | m ² | | | | | |
| ROOF | m ² | | | | | |
| WINDOW GLASS | m ² | | | Coefficient of blind | | |
| | m ² | | | | | |
| | m ² | | | | | |
| | m ² | | | | | |
| PARTITION | m ² | | | 1 | | |
| | m ² | | | | | |
| | m ² | | | | | |
| | m ² | | | | | |
| | m ² | | | | | |
| | m ² | | | | | |
| CEILING | m ² | | | | | |
| FLOOR | m ² | | | | | |
| OUTDOOR AIR | INVASION OF OUTDOOR AIR | Room Volume | m ³ | | Area corr. | |
| | PERSON | Number | | | 1 | |
| LIGHT | Electric Light | | kW | 860 | Rate of using | 1 |
| | Fluorescent Light | | kW | 1000 | | 1 |
| ELECTRIC APPARATUS | | | kW | 860 | | 1 |
| GAS | L.N.G | | m ³ /h | 1000 | 1 | |
| | L.P.G | | m ³ /h | 21700 | 1 | |

TOTAL COOLING LOAD: Q = _____ Kcal/hr
 _____ Btu/hr

*kcal/hr → btu/hr x 3.968



Appendix 2

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

1.3 Coefficient of cooling load


1.3.1 Wall faced to the outdoor
 Table 11-1

| Sort of wall | Coefficient B (kcal/m ² h) | | | | | | | | Coefficient E (kcal/m ² h deg.) |
|---------------------------------------|---------------------------------------|----|----|----|----|----|----|----|--|
| | N | E | S | W | NE | SE | SW | NW | |
| Light construction (wooden, mortar) | 17 | 37 | 29 | 51 | 28 | 34 | 43 | 42 | 2.5 |
| Medium construction (concrete block) | 15 | 40 | 34 | 56 | 32 | 38 | 48 | 45 | |
| Heavy construction (concrete 200mm t) | 16 | 34 | 31 | 37 | 29 | 34 | 40 | 26 | 3.0 |

11.3.2 Roof
 Table 11-2

| Sort of roof | | Coefficient B (kcal/m ² h) | Coefficient E (kcal/m ² h deg.) |
|--|------------|---------------------------------------|--|
| Light construction (slate, mortar or sheet zinc) | No Ceiling | 165 | 3 |
| | Ceiling | 60 | 1.5 |
| Medium construction (thin concrete insulation) | No Ceiling | 92 | 2 |
| | Ceiling | 38 | 1.5 |
| Heavy construction (thick concrete insulation) | No Ceiling | 43 | 1 |
| | Ceiling | 23 | 1 |

(Reference)



Appendix 3

TERBUKA

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

11.3.3 Window glass

Table 11-3

| Sort of glass | Coefficient B (kcal/m ² h) | | | | | | | | | Coefficient E (kcal/m ² h deg.) |
|---------------------------------|---------------------------------------|--------------|-----|-----|-----|-----|-----|-----|-----|--|
| | Shady window | Sunny window | | | | | | | | |
| | | N | E | S | W | NE | SE | SW | NW | |
| Normal glass plate (3 mm thick) | 60 | 150 | 590 | 310 | 710 | 440 | 430 | 530 | 540 | |
| Normal glass plate (6 mm thick) | 55 | 140 | 540 | 290 | 650 | 400 | 390 | 480 | 490 | 5.5 |
| Insulation type (3 mm thick) | 35 | 90 | 370 | 220 | 440 | 270 | 270 | 340 | 340 | |
| Dual glass (6 mm thick inside) | 30 | 70 | 290 | 170 | 340 | 215 | 210 | 260 | 260 | 2.2 |
| Glass block | 25 | 40 | 330 | 130 | 360 | 200 | 190 | 230 | 240 | 2.5 |

Note:

In case more than two windows are provided in different directions, the coefficient B of the window having the largest value of AxB only is taken from the column of "Sunny window" and those of other windows are taken from the column of "Shady window".

A: Area of window

B: Coefficient B

11.3.4 Coefficient of blind attached to window

Table 11-4

| Sort of blind | Coefficient f |
|--|---------------|
| Venetian blind attached to inside of the window. | 0.7 |
| In case of drawing curtain | 0.8~0.7 |

11.3.5 Partition of the room

(In case adjoined rooms are not cooled)

Table 11-5

| Sort of partition | Coefficient B (kcal/m ² h) | Coefficient E (kcal/m ² h deg.) |
|-----------------------|---------------------------------------|--|
| Glass or wooden plate | 13 | 4.5 |
| Others | 8 | 2.7 |

TERBUKA

Continue Appendix 3

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

**11.3.6 Ceiling and floor
 (In case upper and lower rooms are not cooled)**

Table 11-6

| Sort of ceiling and floor | Coefficient B (kcal/m ² h) | Coefficient E (kcal/m ² h deg.) |
|--|--|---|
| Only concrete | 10 | 3 |
| Linoleum or carpet placed on the floor | 7 | 2 |
| Grass mat placed on the wooden floor | 4 | 1 |
| Floor attached on the ground directly | 0 | 1 |

11.3.7 Invasion of outdoor air

Table 11-7

| | Coefficient B (kcal/m ² h) | Coefficient E (kcal/m ² h deg.) |
|--|--|---|
| Standard | 8 | 0.3 |
| Many entrances are in the room. Two or more walls are faced to the outdoor. | 8×(1.5~2) | 0.3×(1.5~2) |

11.3.8 Area correction for outdoor temperature

Table 11-8

| Area (district) | Coefficient f |
|--------------------------|---------------|
| Standard | 1.0 |
| Higher temperature area | 1.1 |
| Highest temperature area | 1.2 |

11.3.9 Occupants

Table 11-9

| Condition of occupants | Application | Coefficient B (kcal/h·person) |
|------------------------|---|----------------------------------|
| Sitting on the chair | Theater, tea room | 100 |
| Office working | Office, hotel, restaurant, department store | 120 |
| Physical working | Factory, dance-hall | 200 |

Continue Appendix 3



FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

Table 5-2a Surface Unit Conductances and Unit Resistances for Air^a

| | | Surface Emittances | | | | | | | | | | | |
|--|------------------------|------------------------------|------------------------|------------------------------|------------------------|------------------------------|------------------------|------------------------------|------------------------|------------------------------|------------------------|------------------------------|------------------------|
| | | $\epsilon = 0.9$ | | | | $\epsilon = 0.2$ | | | | $\epsilon = 0.05$ | | | |
| Position of Surface | Direction of Heat Flow | h | | R | | h | | R | | h | | R | |
| | | Btu hr-ft ² -F | W m ² -C | hr-ft ² -F Btu | m ² -C W | Btu hr-ft ² -F | m ² -C W | Btu hr-ft ² -F | m ² -C W | Btu hr-ft ² -F | m ² -C W | hr-ft ² -F Btu | m ² -C W |
| Still Air | | | | | | | | | | | | | |
| Horizontal | Upward | 1.63 | 9.26 | 0.61 | 0.11 | 0.91 | 5.2 | 1.10 | 0.194 | 0.76 | 4.3 | 1.32 | 0.232 |
| Sloping— 45 degrees | Upward | 1.60 | 9.09 | 0.62 | 0.11 | 0.88 | 5.0 | 1.14 | 0.200 | 0.73 | 4.1 | 1.37 | 0.241 |
| Vertical | Horizontal | 1.46 | 8.29 | 0.68 | 0.12 | 0.74 | 4.2 | 1.35 | 0.238 | 0.59 | 3.4 | 1.70 | 0.298 |
| Sloping— 45 degrees | Downward | 1.32 | 7.50 | 0.76 | 0.13 | 0.60 | 3.4 | 1.67 | 0.294 | 0.45 | 2.6 | 2.22 | 0.391 |
| Horizontal | Downward | 1.08 | 6.13 | 0.92 | 0.16 | 0.37 | 2.1 | 2.70 | 0.476 | 0.22 | 1.3 | 4.55 | 0.800 |
| Moving Air | | | | | | | | | | | | | |
| (any position) | Any | 6.0 | 34.0 | 0.17 | 0.029 | | | | | | | | |
| Wind is 15 mph or 6.7 m/s (for winter) | Any | 4.0 | 22.7 | 0.25 | 0.044 | | | | | | | | |
| Wind is 7½ mph or 3.4 m/s (for summer) | Any | | | | | | | | | | | | |

^a Conductances are for surfaces of the stated emittance facing virtual blackbody surroundings at the same temperature as the ambient air. Values are based on a surface-air temperature difference of 10 F and for a surface temperature of 70 F.

Source: Adapted by permission from ASHRAE Handbook, Fundamentals Volume, 1989.



FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

Thermal Properties of Building and Insulating Materials at a Mean Temperature of 75°F (English Units)

| Material | Description | Density ρ $\frac{lbm}{ft^3}$ | Thermal Conductivity k $\frac{Btu \cdot in}{ft^2 \cdot hr \cdot F}$ | Unit Conductance C $\frac{Btu}{hr \cdot ft^2 \cdot F}$ | Unit Resistance | | | Specific Heat $\frac{Btu}{lbm \cdot F}$ |
|--|---|---|--|---|--|--|------|---|
| | | | | | Per Inch Thickness $\frac{1}{k}$ $\frac{ft^2 \cdot hr \cdot F}{Btu \cdot in}$ | For Thickness Listed $\frac{1}{C}$ $\frac{hf \cdot ft^2 \cdot F}{Btu}$ | | |
| Building Board Boards, panels, subflooring, sheathing, wood-based panel products | Asbestos-cement board ¼ in. or 6 mm | 120 | - | 16.5 | - | 0.06 | 0.24 | |
| | Gypsum of plasterboard ¾ in. or 10 mm | 50 | - | 3.10 | - | 0.32 | 0.26 | |
| | ¾ in. or 10 mm | 50 | - | 2.22 | - | 0.45 | 0.29 | |
| | ½ in. or 13 mm | 34 | 0.80 | - | 1.25 | - | 0.29 | |
| | Plywood ¼ in. or 6 mm | 34 | - | 3.20 | - | 0.31 | 0.29 | |
| | ¾ in. or 10 mm | 34 | - | 2.13 | - | 0.17 | 0.29 | |
| | ½ in. or 13 mm | 34 | - | 1.60 | - | 0.62 | 0.29 | |
| | ¾ in. or 20 mm | 34 | - | 1.07 | - | 0.93 | 0.29 | |
| | Insulating board and sheathing, Regular density ¼ in. or 13 mm | 18 | - | 0.76 | - | 1.32 | 0.31 | |
| | ¾ in. or 20 mm | 18 | - | 0.49 | - | 2.06 | 0.31 | |
| | Hardboard, high density, standard tempered Particle board Medium density Underlayment ¾ in. or 16 mm | 63 | 1.00 | - | 1.00 | - | 0.32 | |
| | | | 50 | 0.94 | - | 1.06 | - | 0.31 |
| | | 40 | - | 1.22 | - | 0.82 | 0.29 | |



FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

Thermal Properties of Building and Insulating Materials at a Mean Temperature of 75°F (English Units) (continued)

| Material | Description | Density ρ $\frac{lbm}{ft^3}$ | Thermal Conductivity k $\frac{Btu \cdot in}{ft^2 \cdot hr \cdot F}$ | Unit Conductance C $\frac{Btu}{hr \cdot ft^2 \cdot F}$ | Unit Resistance | | | Specific Heat $\frac{Btu}{lbm \cdot F}$ |
|----------------------|--|---|--|---|--|--|-------------------|---|
| | | | | | Per Inch Thickness $1/k$ $\frac{ft^2 \cdot hr \cdot F}{Btu \cdot in}$ | For Thickness Listed $1/C$ $\frac{hf \cdot ft^2 \cdot F}{Btu}$ | | |
| | Lightweight aggregate (expanded shale, clay slate or slag, pumice) 3 in. or 75 mm 4 in. or 100 mm 8 in. or 200 mm 12 in. or 300 mm | - | - | 0.79 | - | 1.27 | - | |
| | | - | - | 0.67 | - | 1.50 | - | |
| | | - | - | 0.50 | - | 2.00 | - | |
| | | - | - | 0.44 | - | 2.27 | - | |
| Plastering Materials | Cement plaster, sand, aggregate | 116 | 5.0 | - | 0.20 | - | - | |
| | Gypsum plaster: Lightweight aggregate ½ in. or 13 mm ¾ in. or 16 mm | 45 45 | - - | 3.12 2.67 | - - | 0.32 0.39 | - - | |
| Roofing | Lightweight aggregate on metal lath ¾ in. or 20 mm | - | - | 2.13 | - | 0.47 | - | |
| | Asbestos-cement shingles | 120 | - | 4.76 | - | 0.21 | - | |
| | Asphalt roll roofing | 70 | - | 6.50 | - | 0.15 | - | |
| | Asphalt shingles Built in roofing ¾ in. or 10 mm | 70 | - | 2.27 | - | 0.44 | - | |
| | Slate, ½ in. or 13 mm Wood shingles – plain or plastic film faced | 70 - - | - - - | 3.00 20.00 1.06 | - - - | 0.33 0.05 0.94 | 0.35 - 0.31 | |

Continue Appendix 5



FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
 COURSE NAME : HEATING, VENTILATING & AIR
 CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
 COURSE CODE : BNB 31203

Thermal Properties of Building and Insulating Materials at a Mean Temperature of 75°F (English Units) (continued)

| Material | Description | Density P $\frac{lbm}{ft^3}$ | Thermal Conductivity k $\frac{Btu \cdot in}{ft^2 \cdot hr \cdot F}$ | Unit Conductance C $\frac{Btu}{hr \cdot ft^2 \cdot F}$ | Unit Resistance | | Specific Heat $\frac{Btu}{lbm \cdot F}$ |
|--|---|------------------------------------|--|---|--|--|---|
| | | | | | Per Inch Thickness 1/k $\frac{ft^2 \cdot hr \cdot F}{Btu \cdot in}$ | For Thickness Listed 1/C $\frac{hf \cdot ft^2 \cdot F}{Btu}$ | |
| Loose Fill | Mineral fiber – rock, slag or glass | 0.6 – 2.0 | - | - | - | 11 | 0.17 |
| | Approximately 3.75 – 5 in. or 75 – 125 mm | | | | | | |
| | Approximately 6.5 – 8.75 in. or 165 – 222 mm | 0.6 – 2.0 | - | - | - | 19 | 0.17 |
| | Approximately 7.5 – 10 in. or 191 – 254 mm | - | - | - | - | 22 | 0.17 |
| | Approximately 7 ¼ in. or 185 mm | - | - | - | - | 30 | 0.17 |
| Roof Insulation | Silica aerogel | 7.6 | 0.17 | - | 5.88 | - | - |
| | Vermiculite (expanded) | 7 – 8 | 0.47 | - | 2.13 | - | - |
| | Preformed, for use above deck | - | - | 0.72 | - | 1.39 | - |
| | Approximately ½ in. or 13 mm | - | - | 0.36 | - | 2.78 | - |
| | Approximately 1 in. or 25 mm | - | - | 0.19 | - | 5.56 | - |
| Masonry Materials Concretes | Approximately 2 in. or 50 mm | - | - | - | - | - | - |
| | Cellular glass | 9 | 0.4 | - | 2.5 | - | 0.21 |
| | Lightweight aggregates including expanded shale, clay or slate; | 200 | 5.2 | - | 0.19 | - | - |
| | expanded slags; cinders; | 100 | 3.6 | - | 0.28 | - | - |
| | pumice; vermiculite; also cellular concretes | 80 | 2.5 | - | 0.40 | - | - |
| Sand and gravel or stone aggregate (not dried) | 40 | 1.15 | - | 0.86 | - | - | |
| | | 20 | 0.70 | - | 1.43 | - | - |
| | | 140 | 12.0 | - | 0.08 | - | - |




Continue Appendix 5

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020
COURSE NAME : HEATING, VENTILATING & AIR
CONDITIONING SYSTEM

PROGRAMME CODE : 3BNB
COURSE CODE : BNB 31203



Appendix 6

TERBUKA

FINAL EXAMINATION

SEMESTER / SESSION : SEM I 2019/2020

PROGRAMME CODE : 3BNB

COURSE NAME : HEATING, VENTILATING & AIR
CONDITIONING SYSTEM

COURSE CODE : BNB 31203

FORMULA

$$U = 1 / \Sigma R$$

$$R_x = \Delta x / K_x$$

$$\Sigma R = R_o + \Delta X_1 / K_1 + \Delta X_2 / K_2 + R_i$$

TERBUKA