

CONFIDENTIAL



UNIVERSITI TUN HUSSEIN ONN MALAYSIA

**FINAL EXAMINATION
SEMESTER II
SESSION 2015/2016**

COURSE NAME	:	ENERGY MANAGEMENT & CONSERVATION
COURSE CODE	:	BDE 40203
PROGRAMME	:	4 BDD
EXAMINATION DATE	:	JUNE 2016 / JULY 2016
DURATION	:	3 HOURS
INSTRUCTION	:	ANSWER FIVE(5) OF SIX (6) QUESTIONS

THIS QUESTION PAPER CONSISTS OF EIGHT (8) PAGES

CONFIDENTIAL

- Q1** (a) Efficient Management of Electrical Energy Regulations 2008 (EEMER 2008) gives authority to Energy Commission (EC) to direct premises using a total of 3×10^6 kWh of electrical energy in a period of six consecutive months to appoint a registered electrical energy manager (REEM). Describe the roles of REEM under this regulation.

(8 marks)

- (b) One of the important components of energy management is to conduct energy audit to evaluate energy consumption in a premise. Briefly discuss the three (3) levels of energy audit commonly practiced in the industry.

(12 marks)

- Q2** (a) Calculate the thermal efficiency of a medium-sized boiler, given the operating parameters as following:

- steam output 97,200 kg/h at 40 bar, with $h_g = 2800$ kJ/kg;
- feed water temperature at 91.76°C , with $h_f = 384.44$ kJ/kg;
- fuel consumption of $2.67 \text{ m}^3/\text{s}$ (natural gas with calorific value $36,000 \text{ kJ/m}^3$)

(8 marks)

- (b) Water at 20°C ($\rho = 999.1 \text{ kg/m}^3$ and $\mu = 1.002 \times 10^{-3} \text{ kg/m} \cdot \text{s}$) is flowing steadily in a 30-m-long and 0.5-cm-diameter horizontal steel pipe at a rate of 0.1 L/s. Assuming laminar flow, determine the pumping power required to overcome the pressure drop.

(12 marks)

- Q3** (a) A small factory operating in two shifts of 8 hours each uses 600 kW per hour for the morning shift, and 400 kW per hour for the night shift. Determine the load factor for this operation.

(4 marks)

- (b) Consider the following data: power = 100 kW, current = 500 A, voltage = 240 V. Calculate the power factor if the voltage type is:

- (i) Single phase;
- (ii) Three phase

(4 marks)

- (c) A daily electrical energy usage in an office building is given in **Table Q3 (c)**. Based on the table, determine:

- (i) the total electricity usage in a month (kWh);
- (ii) monthly electricity bill (RM) assuming the premise is subjected to a tariff of 36.5sen/kWh; and
- (iii) Payback period if the office building owner decides to install an energy saving device costing RM 5,000.00 which can reduce the electricity consumption by 15% in a month

(12 marks)

- Q4** (a) Describe the purposes of Malaysian Standard MS1525?

(6 marks)

- (b) A cubical building (10 m x 10 m x 10 m) with glass window on every side of the wall is shown **Figure Q4 (b)**. The opaque wall is made by various materials with properties as in **Table Q4(b, i)** and **Table Q4(b, ii)**. If the solar absorptivity, α of the opaque wall is 0.5 while the shading co-efficient (SC) of the glass window is 0.4, determine:

- (i) the building's Overall Thermal Transfer Value (OTTV); and
- (ii) total wall heat load.

(14 marks)

CONFIDENTIAL

- Q5** (a) Architectural and passive design strategy has been proven to reduce overall energy consumption in buildings. Briefly discuss three (3) of passive design strategies.

(6 marks)

- (b) **Figure Q5 (b)** shows a flat office building roof sketch with 3 skylights. The opaque roof and skylight consist of several components shown in **Table Q5 (b, i)** and **Table Q5 (b, ii)**. The shading co-efficient (SC) of skylight is 0.5 while the equivalent temperature difference is 16°K . Calculate:
- the Roof Thermal Transfer Value (RTTV); and
 - total roof heat load

(14 marks)

- Q6** (a) MS1525 specifies the need for controlling lighting and air conditioning in non-residential buildings. Why is it necessary to have controls?

(6 marks)

- (b) An hotel with a capacity to accommodate 100 peoples has the following data which was obtained from recent energy audit. If the average occupancy rate is 70%, calculate:
- the amount of excess air provided for ventilation;
 - the possible amount of electrical energy reduction; and
 - the total saving (RM) in a year if the building operates 300 days/year and 8 hours/day

Energy audit data of the building:

- Outside/Inside air temperature = $35^{\circ}\text{C} / 25^{\circ}\text{C}$
- Outside/Inside Relative Humidity = $70\% / 50\%$
- Required ventilation/person = 5 litres/s
- Floor area = 500 m^2
- Ventilation duct area = 0.12 m^2
- Incoming air velocity = 2.40 m/s
- COP of the air cond. system = 3.5
- Electricity tariff = RM 0.365/kWh

(14 marks)

-End of Questions-

FINAL EXAMINATION

SEMESTER / SESSION : SEMESTER II / 2015-2016

COURSE

: 4 BDD

SUBJECT : ENERGY MANAGEMENT &
CONSERVATION

SUBJECT CODE

: BDE 40203

Item	Appliance / Equipment	Power rating (Watt)	Usage duration (hour)	Quantity	Days used every month
1	Refrigerator	2,500	22	1	30
2	Air Conditioning	1,500	8	2	24
3	CFL	10	8	32	24
4	Air compressor	20,000	3	1	4
5	Dehumidifier	3,000	4	1	4
6	Industrial Heater	5,000	8	1	4
7	Ceiling Fan	180	8	12	24

Table Q3(c) Electricity usage in the office building

FINAL EXAMINATION

SEMESTER / SESSION : SEMESTER II / 2015-2016

COURSE : 4 BDD

SUBJECT : ENERGY MANAGEMENT & CONSERVATION

SUBJECT CODE : BDE 40203

Individual wall:

$$OTTV = 19.1 \times \alpha \times (1 - WWR) \times U_w + (194 \times CF \times WWR \times SC)$$

Overall:

$$OTTV = \frac{A_1 \times OTTV_1 + A_2 \times OTTV_2 + \dots + A_n \times OTTV_n}{A_1 + A_2 + \dots + A_n}$$




Figure Q4 (b) Building's plan view and side view

Component	R (m ² K/W)
Outside air film	0.051
Gypsum	0.071
Cement Plaster	0.031
Brick wall	0.141
Mosaic	0.011
Inside air film	0.121

Table Q4(b, i) Wall properties

Orientation	N	NE	E	SE	S	SW	W	NW
CF	0.83	1.01	1.15	1.02	0.85	1.02	1.14	0.99

Table Q4(b, ii) Solar Correction Factor

CONFIDENTIAL

FINAL EXAMINATION

SEMESTER / SESSION : SEMESTER II / 2015-2016

COURSE

: 4 BDD

SUBJECT : ENERGY MANAGEMENT & CONSERVATION

SUBJECT CODE

: BDE 40203

$$RTTV = \frac{(A_r \times U_r \times TD_{eq}) + (A_s \times U_s \times \Delta T) + (A_s \times SC \times SF)}{A_0}$$

$$SF = 323 \times CF$$




Figure Q5 (b) Flat RC roof of an office building


Component	R (m ² K/W)
Outside air film	0.051
Cement plaster	0.031
RC Roof	0.171
Fibreglass	2.141
Gypsum board	0.071
Inside air film	0.141

Table Q5(b, i) Components of opaque roof

Component	R (m ² K/W)
Outside air film	0.051
Glass	0.008
Air space	0.175
Inside air film	0.162

Table Q5(b, ii) Components of skylight

A climate of innovation.



NAUTICA DEHUMIDIFIERS, INC.

www.NauticaDehumid.com

1.866.628.8424

PSYCHROMETRIC CHART

Normal Temperature
SI Units

SEA LEVEL

BAROMETRIC PRESSURE: 101.325 kPa




Chart by: HANDS DOWN SOFTWARE, www.handsdownsoftware.com